

COUNTY OF RIVERSIDE

Southwest Justice Center Boiler Repair

RFB# FMARC-317



ADDENDUM NO. 1 March 15, 2024

CERTIFICATION OF RECEIPT OF ADDENDUM

I certify that I have received this addendum on behalf of the company listed below.

Signed: _____ Dated: _____

Name and title: _____

Company: _____

ADDENDUM NO. 1
TO RFB#FMARC-317

1.0 This addendum is considered to be part of the Request for Bids (RFB). All other terms of the RFB remain unchanged and in effect. This addendum is intended to provide additional information and/or to change requirements in the above referenced RFB. Any information contained herein will be considered part of the RFB and as such will be used in the evaluation of the bid responses. Attention all potential bidders, if you have already submitted your proposal prior to the bid closing date, please review this addendum and re-submit your bid response, should this addendum modify your initial bid response.

2.0 To verify that all Vendors have received a copy of this addendum, please sign the cover page of this addendum and **include it in your bid response**. Signed copy of page 1 of this addendum is **required** in the final quote submittal to PublicPurchase.

3.0 Questions & Answers : see next page

4.0 See attached job walk/ bidders conference (SWJC March 13, 2024) sign in sheet.

All other items remain unchanged

Questions & Answers

Q: Do you have a Jurisdiction number & National Board # for the equipment I did not see it on the permit and it will be needed for the R1 code welding.

A: National Board #NB12050 / Jurisdiction#CA1969

Q: Is there more than 163" extending out from the tube sheet to remove the tubes after the Louvers are removed?

A: Yes, we have 132" after the louvers and a little over 4' before the louvers.

Q: Who will be removing the Louvers?

A: Please include in your scope of work.

Q: Are you going to provide the hot work permits and someone to issue a hot work permit to?

A: Yes, you should include the Hot Works permits along with an R-1 inspection report of repairs. Fees for all required permits should be included in the total.

RIVERSIDE COUNTY PURCHASING AND FLEET SERVICES ON BEHALF OF FACILITIES MANAGEMENT

Sign-In Sheet for: ☒ Job Walk ☐ Bid Opening

Name of Project: RFB#FMARC-317 Southwest Justice Center Boiler Repair







Location: Riverside County Southwest Justice Center

30-755 Auld Road
Murrieta CA 92563

Meet at: Front entrance of Justice Center

Date: 3/13/2024

Time: 11AM

Name	Company	Signature	Telephone	E-mail
1. Misty Alderaan, PCS	County Of Riverside		(951) 955-7989	MAAlderaan@Rivco.org
2. Steve McGuire	Southwest Plb		760-343-2345	
3. Day Maly				
4. Mohan Singhal	Porter Boiler		562-397-3333	mohansinghal@porterboiler.com
5. Peter Jellusson	DB Sales		714 334 9329	mett.jellusson@db-sales.com
6. David Kelly	Altoona Boiler		714-319-1242	DKELLY@CALIFORNIAPOWER
7. Joel Ruvalcaba	County of Riverside			
8. Israel Gomez	County of Riverside			
9. Dineka Sutherland	RDM Ennis Surplus		714-390-1711	RDSUTHER@enris.com yaboo.com
10.				
11.				
12.				
13.				